

# MODEL 4410SFRK

# **GENERAL**

Endura II<sup>™</sup> Steel Outdoor Sanitary Freeze-Resistant Single Station Fountain with rounded corner design, heavy-duty steel with textured powder-coat finish and E-Coat immersion for year-round beauty with minimum maintenance. The E-coat immersion process coats the inside and outside for the ultimate in corrosion protection.

## **BUBBLER**

Vandal-resistant bubbler is one-piece, heavy-duty construction. Unit has integral hood guard design to prevent contamination from other users, airborne deposits and tampering.

## SANITARY FREEZE-RESISTANT VALVE SYSTEM

Designed for ground installation 18" minimum below the frost line. Fully sealed assembly minimizes chance of ground water contamination, and prevents drain water from mixing with fresh water.

#### BASIN

Contour-formed stainless steel design with rounded edges reduces splatter, ensures proper drainage and prevents standing water.

#### **PUSHBUTTON ACTUATION MECHANISM**

Self-closing, vandal-resistant pushbutton does not require grasping or twisting.

#### INLET STRAINER

Easily cleaned in-line strainer screen traps particles of 140 microns or larger before they enter the waterway.

## WATER INLET & DRAIN OUTLET

Inlet: 1/2" male NPT fitting. Outlet: Drain requirements are detailed in the owner's manual.

#### ACCESS PANELS

Heavy-gauge steel with vandal-resistant screws. Provides access for easy hook-up of all plumbing connections.

# SUGGESTED SPECIFICATIONS

Unit shall include powder-coated finish with vandal-resistant pushbutton actuation, vandal-resistant bubbler with integral hood guard, and contour-formed rounded basin to reduce splash and prevent standing water. Fountain shall comply with ANSI 117:1 and ADA for visual and motion disabilities. The manufacturer shall certify the unit to meet the requirements of NSF/ANSI 61, and the Safe Drinking Water Act.

Model	Color Option	B	C USA
		ADA Compliant	NSF/ANSI 61 Certified
4410SFRK*	(Refer to Finish Color Options)	•	•

\* Select color option to complete model number. Example: 4410SFRKEVG

#### Each 4410 SFR consists of 2 cartons of the following:

- Fountain
- Single Freeze-Resistant Valve System SANITARYFR1

Note: Continued product improvement makes specifications subject to change without notice. See Halsey Taylor website for most current spec sheet.

Endura II™ Outdoor Tubular Fountain

# Sanitary Freeze-Resistant Single Station



Model 4410SFRK is shown.



FINISH COLOR OPTIONS – Choose color option to complete your model number, add as suffix example: 4410SFRKEVG

Matte finish: DEvergreen = EVG

Gloss finish:

□ Beige = BGE □ Black = BLK □ Blue = BLU □ Brown = BRN	□ Gray = GRY □ Orange = ORN □ Purple = PUR □ Red = RED	☐ Terracotta = TER ☐ White = WHT ☐ Yellow = YLW

#### **OPTIONS**

- Hose Bib (Locking) 4471LHB\* (Choose color option to complete your model number)
- Hose Bib (Non-Locking) 4470NLHB\* (Choose color option to complete your model number)
- Direct Bury Kit 97890C

# Endura II<sup>™</sup> Outdoor Tubular Sanitary Freeze-Resistant Fountain MODEL 4410SFRK

# MOUNTING INSTRUCTIONS and PLUMBING INSTRUCTIONS

Site and drainage excavation is required for fountain installation. Refer to owner's manual for site preparation details. Provide solid, well-drained surface to mount pedestal fountain (concrete pad recommended) with adequate support (300 lb. load minimum). (6) 3/8" minimum fasteners (not included) should be attached securely to mounting surface in order to secure fountain, (Refer to rough-in diagram), and be sure to allow an opening for the freeze-resistant valve in the ground as shown in the installation instructions that accompany the fountain. (Refer to the rough-in diagram below). Refer to local codes for any additional requirements.


Locate and install plumbing through ground as required. Assemble fountain to prepared site and mounting pad.


### NOTE: Fountain is not furnished with service valve.

Position pedestal over plumbing and secure base to fasteners. Remove access panels and connect supply and water lines. Turn on water supply and check for leaks. Refer to owner's manual for detailed instructions.

Reassemble access panels to pedestal. Trap and service stop not included.







halseytaylor.com HALSEY TAYLOR, 2222 Camden Court, Oak Brook, IL 60523

Printed in the U.S.A.